

DATE: February 6, 2008  
 SUBJECT: Monthly Report For January 2008  
 TO: Washington Township Municipal Authority  
 Board of Directors  
 FROM: Omar P Benchhoff, Superintendent

FLOW			1 Hydraulic EDU =228.6 (gpd)		Permitted Hydraulic Capacity 1.94 (MGD)	
MIN.	.620	MGD	EDU's Added last Month	13	Maximum Hydraulic EDU's	8486
AVG.	.730	MGD	EDU's Added This Month	7	Total Hydraulic EDU's Used To Date	5331.5
MAX.	.920	MGD	Total EDU's Added For 2008	7	Available Hydraulic EDU's	3154.5

**The Wastewater Plant Is Currently At 62.8 Percent Of Its Capacity.**

**New Connections:**

11447 Buhrman Dr  
 12325 N Welty Rd  
 12273 Shelby Ave  
 11369 N Landis Ave  
 12378 N Welty Rd  
 12382 N Welty Rd  
 12280 Benning Ave

**Comments:**

- 1) The Sewer Company met all permit parameters during the month of January.
- 2) The biosolids inventory is currently at 54 percent of its capacity.
- 3) No biosolids were recycled during January.

**Major items for the month were:**

- 1) Apparatus Repair & Engineering, Inc (ARE) installed the new control panel at the Sunrise pumping station.

- 2) The two newly installed manholes at the Pennersville job site were successfully vacuum-tested.
- 3) Maintenance personnel removed the #1 pump motor at the Cold Springs pumping station and took to ARE for repair.
- 4) The annual Land Application of Sewage Sludge report was completed and sent to the state of Pa.
- 5) Maintenance personnel replaced the wiring in the conduit going to the screening unit at the Wastewater Treatment Plant.
- 6) The sludge thickener was operated for a total of 68.3 hours and 667,974 gallons of sludge were processed.