

Date: April 7, 2008
 Subject: Monthly Report for March
 To: Washington Township Municipal Authority
 Board of Directors
 From: Omar P. Benchoff, Superintendent

Flow			1 Hydraulic EDU = 228.6 gal/day		Permitted Hydraulic Capacity 1.94 MGD	
Minimum	0.850	MGD	EDU's added last month	9	Maximum Hydraulic EDU's	8486
Average	1.293	MGD	EDU's added this month	10	Total Hydraulic EDU's Used to Date	5350.5
Maximum	3.120	MGD	Total EDU's added for 2007	26	Available Hydraulic EDU's	3135.5

The Wastewater Plant is currently at 63.1 percent of its capacity.

New Connections:

11567 Lady Dell Dr. Lot #75
 11475 Lady Dell Dr. Lot #84
 11439 Lady Dell Dr. Lot #87
 12466 Jackson Ave. Lot #803A
 12468 Jackson Ave. Lot #803B
 12470 Jackson Ave. Lot #803C
 12472 Jackson Ave. Lot #803D
 12474 Jackson Ave. Lot #803E
 12476 Jackson Ave. Lot #803F
 14737 Pennsylvania Ave.

Comments:

1. The Sewer Company met all permit requirements for the month of March.
2. The biosolids inventory is currently at 32 percent of its capacity.
3. 371,700 gallons of biosolids were recycled during March.

Major Items for the month were:

1. On 3/3/08 maintenance personnel replaced the electric heater in the sludge dewatering unit's building.
2. On 3/10/08 maintenance personnel unclogged pump set #2 at the Blue Ridge Summit pumping station.
3. On 3/17/08 maintenance personnel installed the new blower and motor for digesters #1 and #2.
4. On 3/25/08 and again on 3/31/08, maintenance personnel unclogged the main sewer line at the Rt. 16 and Washington Township Blvd intersection.
5. Paramount Feed spread lime on the WTMA farm fields on 3/27/08.

6. On 3/30/08 the sewer main at the intersection of Country Club Rd and Scott Rd. clogged and overflowed before maintenance personnel could unclog it, resulting in a Non-Compliance discharge.
7. The sludge thickener was operated for a total of 59 hours and 577,020 gallons of sludge were processed.