

DATE: August 7, 2008
 SUBJECT: Monthly Report For July
 TO: Washington Township Municipal Authority
 Board of Directors
 FROM: Omar P Benchoff, Superintendent

FLOW			1 Hydraulic EDU =228.6 (gpd)		Permitted Hydraulic Capacity 1.94 (MGD)	
MIN.	.520	MGD	EDU's Added last Month	12	Maximum Hydraulic EDU's	8486
AVG.	.609	MGD	EDU's Added This Month	8	Total Hydraulic EDU's Used To Date	5391.5
MAX.	.860	MGD	Total EDU's Added For 2008	67	Available Hydraulic EDU's	3094.5

The Wastewater Plant Is Currently At 63% Of Its Capacity.

New Connections:

11119B BTE
 11627 Ironwood Dr Lot #43
 12104 BTE
 12846 Mentzer Gap Rd
 11497 Lady Dell Dr Lot #81
 12934 Buchanan Trail East
 15795 Valley Ave Lot #8
 12398 North Welty Ave Lot #78

Comments:

- 1) The Sewer Company met all permit parameters during the month of July.
- 2) The biosolids inventory is currently at 31 percent of its capacity.
- 3) 69,480 gallons of biosolids were recycled during the month of July.

Major items for the month were:

- 1) On 7/02/08 Bob Carpenter and Kyle Davis both passed their CDL driving test.
- 2) On 7/8/08 maintenance personnel flushed and cleaned the sewer lines on Iroquois Ave behind Mountain Gate Restaurant.
- 3) On 7/11/08 maintenance personnel flushed and cleaned a total of seven sewer lines at the Wal-Mart and Lowes parking lots.

- 4) Maintenance personnel pulled both pumps at the Mar-Pen pumping station to clear debris and clean the wet well.
- 5) On 7/16/08 the new meter was installed at the Orchard Rd metering station.
- 6) The sludge thickener was operated for a total of 64.2 hours and 627,884 gallons of sludge were processed.