

DATE: June 2, 2009  
 SUBJECT: Monthly Report for May  
 TO: Washington Township Municipal Authority  
 Board of Directors  
 FROM: Omar P. Benchhoff, Superintendent

FLOW			1 Hydraulic EDU = 228.6 (gpd)		Permitted Hydraulic Capacity 1.94 (MGD)	
MIN.	.900	MGD	EDU's added last month	13	Maximum Hydraulic EDU's	8486
AVG.	1.222	MGD	EDU's added this month	7	Total Hydraulic EDU's used to date	5476.5
MAX	2.480	MGD	Total EDU's added for 2009	49	Available Hydraulic EDU's	3009.5

**For planning purposes the Wastewater Plant is Currently at 64.5% of its Capacity.**

**Connections:**

11987 Oakton Drive Lot#58  
 12400 Polktown Road  
 11510 Lady Dell Dr Lot#69  
 11479 Lady Dell Dr Lot#83  
 11513 Lady Dell Dr Lot#80  
 11502 Lady Dell Dr Lot#68  
 14353 Upper Edgemont Rd

**Comments:**

- 1) The Sewer Plant met all DEP permit parameters during the month of April.
- 2) The biosolids inventory is currently at 26 percent of its capacity.
- 3) 36,000 gallons of biosolids were recycled during May.

**Major items for the month were:**

- 1) On 5/5/09 WTMA personnel Tv-ed sewer laterals on Pennersville Rd.
- 2) On 5/8/09 WTMA maintenance personnel adjusted the #2B decanter weir.

- 3) WTMA personnel have been cleaning and painting at the wastewater pump stations.
- 4) On May 13,14,15<sup>th</sup> WTMA personnel were installing manhole riser rings on Sabillasville Rd and Monterey Lane for a state-paving project.
- 5) On 5/19/09 maintenance personnel removed one of the four pumps at Cold Springs pumping station to remove a piece of 2x2 lumber caught in the impeller.
- 6) Maintenance personnel removed the gas tank on the wastewater plants Dodge pickup truck and replaced a faulty fuel pump.