



NOTE:
This detail is required only when pipe slope is 20% or greater.

Slope	Minimum Anchor Spacing, Center to Center
0.20 - 0.34	35 feet
0.35 - 0.50	25 feet
0.51 +	15 feet or concrete encasement

STANDARD DETAIL
WATER PIPE
SLOPE ANCHOR

WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
SCALE NO SCALE	DWG. NO. P-6