



NOTES:

1. ALL LINES, FITTINGS AND TEST APPURTENANCES SHALL BE CAPABLE OF WITHSTANDING MAXIMUM TEST PRESSURE.
2. WHEN TEST PRESSURE IS LESS THAN PRESSURE RANGE OF METER, INSTALL METER AT ALTERNATE LOCATION SHOWN.
3. PROVIDE ADEQUATE PROTECTION TO ALL LINES, FITTINGS AND TEST APPURTENANCES WHEN TESTING DURING FREEZING WEATHER.
4. PUMP MUST BE CAPABLE OF APPLYING PRESSURE WITHIN TEST RANGE (PROVIDE FOR PRESSURE RELIEF ON PUMP).
5. ELEVATION OF TEST GAUGES MUST BE KNOWN

STANDARD DETAIL
METHOD OF TESTING
WATER MAINS

WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
SCALE NO SCALE	DWG. NO. P-7