



NOTES:

1. INSTALL CONNECTOR LINE FROM EXISTING BLOW OFF ASSEMBLY TO NEW MAIN FOR FILLING, TESTING AND STERILIZING NEW MAIN.
2. CONNECTOR LINE TO BE ASSEMBLED WITH CHECK VALVE AND TO BE OPERATED INDEPENDANT OF EXISTING MAIN.
3. BLOCKING ON EXISTING LINE NOT TO BE DISTURBED.
4. FINAL CONNECTION TO EXISTING MAIN TO BE MADE ONLY AFTER TOTAL PROJECT IS ACCEPTED BY THE UTILITY DEPARTMENT.
5. VALVES ON EXISTING SYSTEM TO BE OPERATED BY WTMA WATER COMPANY EMPLOYEE ONLY.
6. ONLY ONE CONNECTION WILL BE ALLOWED BETWEEN THE EXISTING SYSTEM AND THE NEW CONSTRUCTION UNTIL TESTING AND DISINFECTION IS COMPLETE.
7. USE OF THE EXISTING MAIN TO FILL THE NEW WATER MAIN MUST BE PRE-APPROVED BY THE WTMA.
8. THE USE OF FIRE HYDRANTS OR TAPPING THE EXISTING MAIN ARE ALTERNATIVE MEANS OF FILLING NEW MAIN.

**STANDARD DETAIL
JUMPER CONNECTION**

WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
SCALE NO SCALE	DWG. NO. P-8