



NOTE:

1. BACKFILL AND COMPACTION REQUIREMENT APPLIES TO PAVED ROADWAYS AND SHOULDERS OF PROPOSED AND EXISTING STREETS (OTHER THAN STATE HIGHWAYS), PAVED DRIVEWAYS, AND SIDEWALKS.
2. ALL WATER SYSTEM PIPING SHALL HAVE A MINIMUM 4' DEPTH AND MAXIMUM 7' DEPTH.

STANDARD DETAILS
**TRENCH BACKFILL DETAIL
 IN PAVED AREAS**

WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
11/07	DWG. CREATED
SCALE NO SCALE	DWG. NO. TR-W1