



**NOTE:**

1. ALL WATER SERVICE PIPING SHALL HAVE A MINIMUM 4' DEPTH AND A MAXIMUM 7' DEPTH.
2. ENGINEER MAY APPROVE GREATER THAN 7' COVER ON A CASE-BY-CASE BASIS.

STANDARD DETAILS  
**TRENCH BACKFILL DETAIL**  
 IN UNPAVED AREAS  
 WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
11/07	DWG. CREATED
SCALE NO SCALE	DWG. NO. TR-W2