



NOTE: ALL PIPE IN CONTACT WITH CONCRETE SHALL BE WRAPPED WITH 8 MILS OF POLYWRAP PRIOR TO POURING CONCRETE

STANDARD DETAILS

CONCRETE ENCASEMENT DETAIL

WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
11/07	DWG. CREATED
SCALE NO SCALE	DWG. NO. TR-W5