

METER SIZE	BYPASS SIZE	W/CHECK VALVE	W/O CHECK VALVE	B	C	E
		A	A			
<b>COMPOUND METERS</b>						
2"	1"	5'-7"	4'-11"	4'-10"	2'-5"	3'-1"
3"	1-1/2'	6'-2"	5'-4"	5'-0"	2'-6"	3'-2 1/2"
4"	2'	6'-9"	5'-9"	5'-0"	2'-6"	3'-4"
6"	3"	7'-6"	6'-4"	5'-3"	2'-8"	3'-5"
8"	4"	9'-0"	6'-10"	5'-4"	2'-8"	3'-9"
10"	6"	9'-2"	7'-4"	5'-10"	2'-11"	3'-11"
<b>DETECTOR CHECK METERS</b>						
4"	2"	_____	4'-9"	5'-7"	3'-1"	3'-1"
6"	3"	_____	5'-3"	5'-10"	3'-2"	3'-5"
8"	4"	_____	5'-7"	6'-2"	3'-5"	3'-11"
10"	6"	_____	6'-4"	6'-6"	3'-7"	4'-2"
<b>F.M. METERS</b>						
4"	2"	7'-2"	6'-1"	6'-0"	3'-9"	3'-2"
6"	4"	8'-6"	7'-1"	6'-6"	4'-3"	3'-7"
8"	6"	9'-4"	7'-9"	7'-3"	4'-9"	4'-0"
10"	8"	11'-1"	9'-0"	8'-0"	5'-6"	4'-7"

NOTES:

- SEE DETAIL V-9 FOR METER INSTALLATION DETAILS.

STANDARD DETAIL  
 DIMENSIONS FOR COMPUND,  
 DETECTOR CHECK AND F.M.  
 METER INSTALLATION  
 WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY

DATE	REVISIONS
SCALE NO SCALE	DWG. NO. V-8