



1. ALL STORN DRAIN CROSSINGS SHALL BE ENGINEERED TO PROTECT THE STRUCTURAL INTEGRITY OF THE MAIN.
2. CLAY DIKES SHALL BE REQUIRED TO PREVENT SURFACE WATER INTRUSION INTO BEDDING.
3. THERE SHALL BE A 18 INCH SEPARATION BETWEEN THE TOP OF THE WATER MAIN AND BOTTOM OF STORM DRAIN.
4. NO LESS THAN 4 FEET OR MORE THAN 7 FEET OF COVER SHALL BE PLACED OVER THE WATER MAIN.

STANDARD DETAIL  CONSTRUCTED EMBANKMENT TO PROVIDE MIN. REQ'D WATER LINE COVER  WASHINGTON TOWNSHIP MUNICIPAL AUTHORITY	DATE    	REVISIONS    
SCALE NO SCALE		DWG. NO. W-3