

DATE: July 5, 2011  
 SUBJECT: Monthly Report for June 2011  
 TO: Washington Township Municipal Authority  
 Board of Directors  
 FROM: Omar P. Benchoff, Superintendent

FLOW			1 Hydraulic EDU = 228.6 (gpd)		Permitted Hydraulic Capacity 1.94 (MGD)	
MIN.	.530	MGD	EDU's added last month	0	Maximum Hydraulic EDU's	8486
AVG.	.615	MGD	EDU's added this month	0	Total Hydraulic EDU's used to date	5659.5
MAX	.910	MGD	Total EDU's added for 2011	3	Available Hydraulic EDU's	2826.5

**For planning purposes the Wastewater Plant is currently at 66.7% of its capacity.**

**Connections:**

No connections for June.

**Comments:**

- 1) The Wastewater Department met all permit parameters during the month of June.
- 2) The biosolids inventory is currently at 34% of its capacity.
- 3) No biosolids were recycled during June.

**Major items for the month were:**

- 1) WTMA maintenance personnel repaired several holes on the steel roof of the white storage building and then applied two coats of roof cement on the entire roof.
- 2) WTMA maintenance personnel repaired several air leaks going into SBR #2.
- 3) On 6/14/11 WTMA hired DL George's crane service to replace a faulty mixer motor on SBR #1 with a rebuilt unit.
- 4) WTMA maintenance personnel serviced and checked the Ford Escape for inspection.
- 5) WTMA personnel cleaned several main sewer lines: the first was behind Mountain Gate Restaurant on Iroquois Trail, and it was clogged with grease; the second was at the intersection of Linda Lane and Long View. WTMA personnel also cleaned the main line coming from Waynesboro Country Club, and it was partially clogged with grease. They also cleaned the line off of Rt16 across from Mountain Shadows Restaurant, and found a small accumulation of grease.
- 6) WTMA maintenance personnel installed new brakes and checked the sewer plant's Ford dump Truck for inspection.

- 7) WTMA maintenance personnel repaired a broken exhaust manifold stud on the sewer plants 4x4 Chevy truck.