

DATE: May 13, 2013
 SUBJECT: Monthly Report for April 2013
 TO: Washington Township Municipal Authority
 Board of Directors
 FROM: Omar P. Benchoff, Superintendent

FLOW			1 Hydraulic EDU = 228.6 (gpd)		Permitted Hydraulic Capacity 1.85 (MGD)	
MIN.	.500	MGD	EDU's added last month	0	Maximum Hydraulic EDU's	8092
AVG.	.609	MGD	EDU's added this month	6	Total Hydraulic EDU's used to date	5684.5
MAX	.780	MGD	Total EDU's added for 2012 and 2013	2012 12 2013 7	Available Hydraulic EDU's	2406.5

For planning purposes the Wastewater Plant is currently
 at 70.2% of its capacity.

Connections:

13737 Marway Lane Lot #9
 12197 Forest Hill Road Lot #232
 13755 Marway Lane Lot #10
 13963 Anthony Highway – Tap Fee committed
 13943 Anthony Highway – Tap Fee committed
 13933 Anthony Highway – Tap Fee committed

Comments:

- 1) The Wastewater Department met all permit parameters during the month of April.
- 2) The biosolids inventory is currently at 20% of its capacity.
- 3) 370,800 gallons of biosolids were recycled during April.

Major items for the month were:

- 1) WTMA maintenance personnel installed a new pressure switch on the sludge dewatering unit.
- 2) WTMA maintenance personnel installed new blades and serviced the Kabota lawn mower.
- 3) WTMA personnel installed a new refrigerator in the influent composite sampler.
- 4) WTMA maintenance personnel serviced the grit removal system.
- 5) Envirep TLC replaced the logic controller at the Blue Ridge Summit pump station.
- 6) On 4/18/13 WTMA received a visit from DEP on an odor complaint; DEP did an inspection and found nothing wrong. The odor control system is set to come on at 10AM and turn off at 9PM.
- 7) WTMA maintenance personnel greased all the mixer motors.
- 8) WTMA personnel repaired the spreader on the big wheeled sludge truck.