

DATE: April 10, 2014
 SUBJECT: Monthly Report for March 2014
 TO: Washington Township Municipal Authority
 Board of Directors
 FROM: Omar P. Benchoff, Superintendent

FLOW			1 Hydraulic EDU = 228.6 (gpd)		Permitted Hydraulic Capacity 1.85 (MGD)	
MIN.	.710	MGD	EDU's added last month	0	Maximum Hydraulic EDU's	8092
AVG.	.957	MGD	EDU's added this month	0	Total Hydraulic EDU's used to date	5750.5
MAX	2.070	MGD	Total EDU's added for 2012 and 2013	2013 73 2014 0	Available Hydraulic EDU's	2340.5

For planning purposes the Wastewater Plant is currently at 71.0% of its capacity.

Connections: No connections for March

Comments:

- 1) The Wastewater Department met all permit parameters during the month of March.
- 2) The biosolids inventory is currently at 65% of its capacity.
- 3) No biosolids were recycled during the month of March.

Major items for the month were:

- 1) WTMA personnel replaced a serpentine belt tensioner on the 2008 Ford service truck.
- 2) WTMA personnel cleaned three truck loads of grit and mud out of the grit removal system.
- 4) WTMA maintenance personnel readied the 2001 Chevy 4x4 and the Jet Vac truck for inspection.
- 5) WTMA maintenance personnel serviced the Wastewater Plant standby generator.
- 6) On 3/24/14 WTMA personnel used the Jet Vac truck to unclog an overflowing man-hole in front of the Mountain Shadows Restaurant.
- 7) WTMA maintenance personnel serviced the Wastewater Plant's Jet Vac truck.
- 8) WTMA serviced all of the Wastewater Plant's lawn mowers.