

MONTHLY REPORT FOR JANUARY 2022

WASTEWATER REPORT

TO: Washington Township Municipal Authority Board of Directors
 FROM: Joe Schorn
 DATE: February 10, 2022

FLOW			1 HYDRAULIC EDU = 228.6 (gpd)		PERMITTED HYDRAULIC CAPACITY 1.85 (MGD)	
MIN.	0.720	MGD	EDU's added last month	0	Maximum Hydraulic EDU's	8092
AVG.	0.800	MGD	EDU's added this month	3	Total Hydraulic EDU's used to date	6144
MAX	0.960	MGD	Total EDU's added for 2020 and 2021	2021 92 2022 3	Available Hydraulic EDU's	1951

MONTHLY RAINFALL AT THE PLANT: 1.51"

FOR PLANNING PURPOSES THE WASTEWATER PLANT IS CURRENTLY @ 76% OF ITS CAPACITY

NEW CONNECTIONS:

10895 Mentzer Gap Road
 11318 weatherstone Drive Lot #200
 4437 Buchanan Trail East


COMMENTS:

1. The bio-solids inventory is currently at 10% of its capacity.

MAINTENANCE:

1. The staff serviced the pumps at B.R.S. pump station.
2. The staff is working on organizing O&M manuals and important documents so they are easily found.
3. The staff is working on inventoring all tools, part, lab supplies, pumps, and motors at the WWTP.
4. The staff had to rod out a part of our main line on Old Route 16 due to grease build up. I have talked to Jeremy Morris and we are going to do our fat oils and grease checks this spring through out the TWP.
5. I have sent our LASS report to DEP, this is the yearly bio-solids report that is due in March.

Respectfully Submitted,


 Joe Schorn
 Director of Utilities