

TO: WTMA Board of Directors
FROM: Scott Melego, Water Superintendent
DATE: April 14, 2009
SUBJECT: Monthly Water Report for March 2009

This month the water system
was operating at 40% of capacity.

MONTHLY

WATER PRODUCED: 14,798,000 GALLONS

* Note that the Monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.

LOSS FROM LEAKS: 142,560 GALLONS 0.96%

LOSS FROM FLUSHING, FIRE
PROTECTION & BLOW OFFS: 231,000 GALLONS 1.56%

PREVIOUS SYSTEM CONNECTIONS: 2,227

NEW CONNECTIONS THIS MONTH: 4

TOTAL SYSTEM CONNECTIONS: 2,231

TOTAL CONNECTIONS FOR 2009 12

NEW CONNECTION LOCATIONS: 11485 Mystic Rock Ln Lot #15 11455 Buhrman Dr. Lot#19
11418 Buhrman Dr. Lot#64 11533 Mystic Rock Ln Lot #11

(A.) 2 Leaks were discovered and repaired this month.

1. Leak 11601 Old Route 16, 5/8 meter bottom blew out, meter was replaced with a radio read meter.
2. Leak on a 2 inch Air release valve located on a 8 inch mainline that feeds the upper parts of Weatherstone.

(B.) Additional Maintenance / Repair Work.

1. The water company helped tear down the E & S controls at the new well site.
2. Returned 10 unused filter bags from the well drilling site to L/B Water.
3. Univar delivered 15, one barrel was leaking. Returned the leaking barrel and also received 1 barrel of Aqua-Mag.
4. Villa View Pump Station power was disconnected due to a truck delivering materials. A police report was filed.
5. A new Air release valve was installed at the Skiway booster station.
6. Sulphur Springs pump stopped pumping, found particles stuck in the impeller, ordered another pump as back up.
7. The water company cleaned out the basement of the old office building.
8. Sean, Scott and Rodney attended the Ground Water Rule Training in Gettysburg by D.E.P.
9. The generator at Brookdale was exercised.
10. Oyers requested the water company help read their individual water meters, they were billed appropriately.
11. Completed all lawn restorations from previous leaks.
12. Replaced 17 meters that had over 1 million gallons on them with Radio Read meters.
13. Water operators continue to draw up all service line connections and indicate curbstop, and meter location.
14. Eye wash stations were flushed and re-filled with Eyesaline at all of the source stations.

Respectfully submitted,

Scott Melego
Water Superintendent
WTMA Water Dept.