

TO: WTMA Board of Directors  
FROM: Scott Melego, Water Superintendent  
DATE: January 15, 2010  
SUBJECT: Monthly Water Report for December 2009

This month the water system  
was operating at 42% of capacity.

MONTHLY

WATER PRODUCED:	15,234,000	GALLONS	
* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.			
LOSS FROM LEAKS:	0	GALLONS	0.00%
LOSS FROM FLUSHING, FIRE PROTECTION & BLOW OFFS:	358,160	GALLONS	2.35%
PREVIOUS SYSTEM CONNECTIONS:	2,245		
NEW CONNECTIONS THIS MONTH:	1		
TOTAL SYSTEM CONNECTIONS:	2,246		
TOTAL CONNECTIONS FOR 2010	28		
NEW CONNECTION LOCATIONS:	11928 Deerfield Circle		

(A.) 0 Leak was found and repaired this month.

(B.) Additional Maintenance / Repair Work.

1. The snow plow was painted and other items were maintenance for wintertime use.
2. WTMA borrowed the "line locator" from the Borough of Waynesboro for locating lines through Buena Vista.
3. A valve box cleaning tool was repaired by operators and some valve boxes were cleared of debris in the system.
4. The Hoover Springs Cl2 line strainer was cleaned and verified that normal pressures are being achieved for chlorination. Also, the intake screen was cleared of debris.
5. The WTMA received a new fiberglass door from Dyer Fiberglass Inc. for the Hoover Springs building.
6. Operators replaced 4 meters that had over 1 million gallons on them.
7. A total of 86 that had over 1 million gallons on them were replaced for the year 2009.
8. Operators installed a new meter register at Well #10.
9. New tires were purchased for the 2005 Blazer and 2005 pick up truck.
10. A draft document was produced by Whel-Tech for the Ground Water Rule to meet the requirements by Oct 1, 2010.
11. Operators repaired a broken valve box along the Blvd.
12. Snow and sidewalks at the pump stations were cleared of snow as necessary.

Respectfully Submitted,

Scott Melego  
Water Superintendent  
WTMA Water Dept.