

TO: **WTMA Board of Directors**  
FROM: Rodney Eberly, Water Superintendent  
DATE: July 9, 2010  
SUBJECT: Monthly Water Report for June 2010

The monthly water system was operating at 49% of capacity.

MONTHLY

WATER PRODUCED: 18,223,000 GALLONS

\* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.

LOSS FROM LEAKS: 2,883,664 GALLONS 15.82%

LOSS FROM FLUSHING, FIRE PROTECTION & BLOW OFFS: 174,800 GALLONS 0.96%

PREVIOUS SYSTEM CONNECTIONS: 2,261

NEW CONNECTIONS THIS MONTH: 1

TOTAL SYSTEM CONNECTIONS: 2,261 1 service was disconnected @ 10471 BTE

TOTAL CONNECTIONS FOR 2010 16

NEW CONNECTION LOCATIONS: 13242 Mentzer Gap Rd.


(A.) 6 Leaks were discovered and repaired this month.

1. East Ave & South Ave. 1" leak on a 2" main.
2. Mentzer Ln. 3 leaks on the 1" and 2" main.
3. Airport Rd. leak on service line at the curb stop.
4. Church St. leak on the customers side of the curb valve.

(B.) Additional Maintenance / Repair Work.

1. Finished the chlorine degradation study and submitted results to DEP.
2. The Water department started an aggressive in-house leak detection program. We have found approximately 12 leaks in the past 3 1/2 weeks. Letters have been sent to customers with leaks on their service lines.
3. Operators performed mowing, cleaning and general maintenance as necessary.
4. Green Ridge pump # 1 went down, A R & E pulled the pump and are in the process of repairing it.
5. Completed the Consumer Confidence Report for 2009 it was to be sent to the DEP and customers by July 1st 2010.
6. PSI working on the pilot valve for the 4" PRV in the Beartown pit.
7. Operators repaired the exit device for the main door at Wells 5 & 6.
8. The Water department purchased a Metrotech 810 DX-R line locator. The new locator has already shown its worth by locating a service line and curb valve on Norwood Ave.
9. We received the second of five chlorine analyzer/Mission units and installed the units at Bubbling Springs.

Respectfully Submitted,



Rodney Eberly  
Water Superintendent  
WTMA Water Dept.