

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: January 11, 2011
SUBJECT: Monthly Water Report for December 2010

This month the water system was operating at 41% of capacity.

MONTHLY

WATER PRODUCED:	14,848,000	GALLONS	
* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.			
LOSS FROM LEAKS:	0	GALLONS	0.00%
LOSS FROM FLUSHING, FIRE PROTECTION & BLOW OFFS:	446,400	GALLONS	3.01%
PREVIOUS SYSTEM CONNECTIONS:	2,274		
NEW CONNECTIONS THIS MONTH:	1		
TOTAL SYSTEM CONNECTIONS:	2,275		
TOTAL CONNECTIONS FOR 2010	30		
NEW CONNECTION LOCATIONS:	11411 Burhman Dr East		

(A.) 1 Leak was found this month.

1. Monterey Circle, this leak was metered.

(B.) Additional Maintenance / Repair Work.

1. Five blow-offs were opened for the winter, estimated water loss of 14,400 gallons per day.
2. Power Systems performed routine maintenance on all four generators.
3. Operators continued leak detection through-out the system.
4. Main valves, curb stops and meter pits were marked for the winter.
5. A new 3/4" tap was installed on Mentzer Gap Road for a lot subdivision.
6. Univar delivered 24 drums of caustic soda and 4 bottles of chlorine.
7. Several main line valve boxes were cleaned and proper operation was verified.
8. The water depart. responded to a hand full of frozen water line issues, most were on the customers side.
9. The first steps were taken to install a master meter at the Laurel Acres trailer park.

Respectfully Submitted,

Rodney Eberly
Water Superintendent
WTMA Water Dept.