

TO: WTMA Board of Directors
 FROM: Rodney Eberly, Water Superintendent
 DATE: February 8, 2011
 SUBJECT: Monthly Water Report for January 2011

This month the water system was operating at 42% of capacity.

* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.

	<u>MONTHLY</u>			<u>QUARTERLY</u>	
WATER PRODUCED:	15,640,000	GALLONS		45,138,000	GALLONS
WATER SOLD:				29,734,000	GALLONS
LOSS FROM LEAKS:	1,000,000	GALLONS	6.39%	2,800,000	GALLONS
LOSS FROM FLUSHING, FIRE PROTECTION & BLOWOFFS:	525,000	GALLONS	3.36%	975,400	GALLONS
UNACCOUNTED WATER LAST OTR:				14%	
UNACCOUNTED WATER THIS QTR:				26%	
PREVIOUS SYSTEM CONNECTIONS:				2,275	
NEW CONNECTIONS THIS MONTH:				0	
TOTAL SYSTEM CONNECTIONS:				2,275	
TOTAL CONNECTIONS FOR 2011				0	
NEW CONNECTION LOCATIONS:					


(A.) 0 Leaks were discovered this month.

Several unmetered leaks inside the Laurel Acres trailer park remain un-repaired.

(B.) Additional Maintenance / Repair Work.

1. Operators performed routine maintenance on all chemical feed pump:
2. Notices were posted for shut-offs.
3. All water department employees received their annual evaluations.
4. Customers were shut-off due to non-payment.
5. Meter reading and re-checks were completed this month despite several snow events.
6. Staff performed snow removal as needed.
7. A new CL2 booster pump was installed at Well # 10, the old pump will be sent out for repairs.
8. Blow-offs remain open for the winter months.
9. Interior house cleaning and general maintenance issues were completed.
10. Received a time extension from DEP for the 2010 Allocation report, this is routine as our last billing cycle ends in January.
11. John K. and Tim M. attended a meter and hydrant seminar in Gettysburg.
12. In-house leak detection was severely curtailed this month due to weather, however there are still leaks in the Laurel Acres trailer park that have yet to be repaired. The master meter installation has been set back due to weather issues.

Respectfully Submitted,



Rodney Eberly
 Water Superintendent
 WTMA Water Dept.