

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: June 12, 2013
SUBJECT: Monthly Water Report for May 2013

This month the water system
was operating at 47% of capacity.

MONTHLY

WATER PRODUCED: 16,817,000 GALLONS

* Note that the monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.

ESTIMATED LOSS FROM KNOWN LEAKS: 9,452,000 GALLONS

ESTIMATED LOSS FROM FLUSHING, FIRE
PROTECTION & BLOW OFFS: 110,000 GALLONS

PREVIOUS SYSTEM CONNECTIONS: 2,300

NEW CONNECTIONS THIS MONTH: 0

TOTAL SYSTEM CONNECTIONS: 2,300

TOTAL CONNECTIONS FOR 2012/2013 16/3

NEW CONNECTION LOCATIONS: NONE


(A.) 7 Leaks were discovered this month.

1. 14100 BTE. Customer discovered this leak. Leak was metered.
2. Blondies. Staff discovered this leak. 3/8" hole. 2,363,000 gallons
3. Lower Edgemont Road. Staff discovered this leak. 3/8" hole. 2,363,000 gallons
4. 14715 Charmian Road. Staff discovered this leak. 1/4" hole. 1,181,500 gallons
5. 12372 Charmian Lane. Staff discovered this leak. 1/4" hole. 1,181,500 gallons
6. Flohr Lane. Staff discovered this leak. 1/4" hole. 1,181,500 gallons
7. 12115 Snyder Ave. Staff discovered this leak. 1/4" hole. 1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. Aqua Tech completed their leak survey, finding 11 leaks.
2. All stations were cleaned and organized for spring.
3. The front spindle on the John Deere mower was replaced.
4. Kim Snook with PADEP completed a full inspection of the water system.
5. Line tracing was done to verify locations with the GIS.
6. Several lawns were restored following leak repairs.
7. All radio read meter pits were inspected as part of leak detection

Respectfully Submitted,


Rodney Eberly
Water Superintendent
WTMA Water Dept.