

TO: WTMA Board of Directors  
FROM: Rodney Eberly, Water Superintendent  
DATE: March 19, 2014  
SUBJECT: Monthly Water Report for February 2014

This month the water system  
was operating at 43% of capacity.

MONTHLY

WATER PRODUCED:	14,084,000	GALLONS	
* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.			
EST LOSS FROM KNOWN LEAKS:	1,681,500	GALLONS	11.94%
EST LOSS FROM FLUSHING, FIRE PROTECTION & BLOW OFFS:	395,000	GALLONS	2.80%
PREVIOUS SYSTEM CONNECTIONS:	2,363		
NEW CONNECTIONS THIS MONTH:	3		
TOTAL SYSTEM CONNECTIONS:	2,366		
TOTAL CONNECTIONS FOR 2013/2014	66/ 3		

NEW CONNECTION LOCATIONS:

1. 11537 Buhrman Drive East
2. 11523 Buhrman Drive East
3. 9930 Skittle Court

(A.) 2 Leaks were found and repaired this month.

1. 15208 Ressler Lane, customer discovered this leak. 1/4" hole. 1,181,500 gallons
2. Boulevard PRV pit, Resident discovered this leak. 500,000 gallons

(B.) Additional Maintenance / Repair Work.

1. The sump pump at Wells 5 & 6 was replaced.
2. Operators performed maintenance on the meter routes.
3. Tim Moore attended training in Gettysburg.
4. Tim Moore and Brad Martin were re-certified for flagging.
5. The 3" trash pump was serviced this month.
6. A new air compressor was purchased for Well 10.
7. Snow removal was performed as necessary.
8. Operators repaired the damaged PRV in the Boulevard pit.

Respectfully Submitted,



Rodney Eberly  
Water Superintendent  
WTMA Water Dept.