

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: January 9, 2015
SUBJECT: Monthly Water Report for December 2014

This month the water system
was operating at 45% of capacity.

MONTHLY

WATER PRODUCED: 16,173,000 GALLONS

* Note that the Monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.

EST LOSS FROM KNOWN LEAKS: 1,181,500 GALLONS 7.31%

Also added leaks on customers side to the leak total that was unmetered.

EST LOSS FROM FLUSHING, FIRE

PROTECTION & BLOW OFFS: 675,000 GALLONS 4.17%

PREVIOUS SYSTEM CONNECTIONS: 2,395

NEW CONNECTIONS THIS MONTH: 0 14326 BTE was disconnected.

TOTAL SYSTEM CONNECTIONS: 2,394

TOTAL CONNECTIONS FOR 2013/2014 66/ 32

NEW CONNECTION LOCATIONS:

(A.) 1 Leak was found and repaired this month.

Snyder Ave. Leak was discovered by staff. 1/4" hole. 1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. A new fan motor was installed in the heater at the Brookdale building.
2. Operators completed the VOC sampling for the year.
3. The caustic pump was cleaned at Wells 5 & 6.
4. A.R. & E. installed 2 new VFD drives at the Edgewood booster station.
5. A water service was disconnected at 14326 BTE.
6. WTMA's meter replacement program continues as staff replaces million gallon meters.
7. Operators performed leak detection as time permits.
8. A corporation stop was dug up on Seth Lane and found in the off position.
9. The rotometer was cleaned at Well 10.

Respectfully Submitted,



Rodney Eberly
Water Superintendent
WTMA Water Dept.