

TO: WTMA Board of Directors
 FROM: Rodney Eberly, Water Superintendent
 DATE: February 3, 2015
 SUBJECT: Monthly Water Report for January 2015

This month the water system
 was operating at 46% of capacity.

* Note that the Monthly loss from leaks is based on a calculation that can
 be calculated up to 3 months depending on site description and certain characteristics of the leak.

	<u>MONTHLY</u>			<u>QUARTERLY</u>	
WATER PRODUCED:	17,076,000	GALLONS		48,304,000	GALLONS
WATER SOLD:				30,314,100	GALLONS
EST. LOSS FROM KNOWN LEAKS:	3,544,500	GALLONS	20.76%	7,139,000	GALLONS
EST. LOSS FROM FLUSHING, FIRE PROTECTION & BLOWOFFS:	925,000	GALLONS	5.42%	2,215,000	GALLONS
UNACCOUNTED WATER LAST OTR:				4%	
UNACCOUNTED WATER THIS QTR:				18%	
PREVIOUS SYSTEM CONNECTIONS:				2,394	
NEW CONNECTIONS THIS MONTH:				2	
TOTAL SYSTEM CONNECTIONS:				2,396	
TOTAL CONNECTIONS FOR 2014/2015				32/ 2	

NEW CONNECTION LOCATIONS:
 9921 Skittle Run Court
 14460 Upper Edgemont Road


(A.) 2 Leaks were discovered and repaired this month.

Snyder Ave. 1/4" hole. Staff discovered leak.	1,181,500 gallons
Red Bud subdivision air release. 3/8" hole. Customer discovered leak.	2,363,000 gallons

(B.) Additional Maintenance / Repair Work.

1. The site gauge float in the large tank on Tower Road was repaired.
2. Operators posted shut off notices.
3. All meters were read and re-checks were verified.
4. Operators used the leak detection equipment to assist a customer locate a leak on their service line.
5. The drive belt on the caustic pump at Bubbling Springs was replaced.
6. All CL2 feed lines and fittings were replaced at all stations as part of our general preventative maintenance.
7. An air release valve in the Red Bud development was repaired after it developed a leak in the 2' line that connects it to the water main.

Respectfully Submitted,


 Rodney Eberly
 Water Superintendent
 WTMA Water Dept.