

TO: WTMA Board of Directors  
FROM: Rodney Eberly, Water Superintendent  
DATE: March 12, 2015  
SUBJECT: Monthly Water Report for February 2015

This month the water system  
was operating at 49% of capacity.

MONTHLY

WATER PRODUCED:	16,231,000	GALLONS	
* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.			
EST. LOSS FROM KNOWN LEAKS:	2,453,000	GALLONS	15.11%
EST. LOSS FROM FLUSHING, FIRE PROTECTION & BLOW OFFS:	1,050,000	GALLONS	6.47%
PREVIOUS SYSTEM CONNECTIONS:	2,396		
NEW CONNECTIONS THIS MONTH:	1		
TOTAL SYSTEM CONNECTIONS:	2,397		
TOTAL CONNECTIONS FOR 2014/2015	32/ 3		
NEW CONNECTION LOCATIONS:			
11606 Honey Run Court			

(A.) 3 Leaks were found and repaired this month.


Red Bud PRV Pit. Staff discovered leak.  
12723 Skiway. Staff discovered leak.  
Seth Lane. Customer discovered leak.

90,000 gallons  
1,181,500 gallons  
1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. The Caustic feed line at Wells 5 & 6 was repaired.
2. A new heater was installed in the pump building at Wells 5 & 6.
3. The clear well at Hoover Springs was drained and cleaned.
4. Most of the time this month was devoted to snow removal, frozen meters, and frozen service lines.

Respectfully Submitted,



Rodney Eberly  
Water Superintendent  
WTMA Water Dept.