

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: April 20, 2015
SUBJECT: Monthly Water Report for March 2015

This month the water system
was operating at 52% of capacity.

MONTHLY

WATER PRODUCED: 19,141,000 GALLONS

* Note that the Monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.

EST. LOSS FROM KNOWN LEAKS: 2,363,000 GALLONS 12.35%

EST. LOSS FROM FLUSHING, FIRE
PROTECTION & BLOW OFFS: 975,000 GALLONS 5.09%

PREVIOUS SYSTEM CONNECTIONS: 2,397

NEW CONNECTIONS THIS MONTH: 1

TOTAL SYSTEM CONNECTIONS: 2,398

TOTAL CONNECTIONS FOR 2014/2015 32/ 4

NEW CONNECTION LOCATIONS:
9968 Skittle Run Court

(A.) 2 Leaks were discovered and repaired this month.

Charmian Lane, frozen meter. Staff discovered leak	1,181,500 gallons
Church Street, leak on customers service line. Customer discovered leak.	1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. Installed a new 2" line on Ridgeway, the existing line was frozen.
2. Leak detection was performed as time permitted.
3. Operators spent a considerable amount of time thawing meters and service lines.
4. The 8" PRV in the Boulevard pit was rebuilt.
5. The 8" control valve at Brookdale was rebuilt.
6. One of the fire flow meters at New Forge Crossing froze and burst.
7. The Caustic line at Wells 5 & 6 was repaired.
8. Installed a new 2" line on Lumber Lane.
9. Operators tapped the water main on Old Pen Mar Road for several new lots.

Respectfully submitted,

Rodney Ebely
Water Superintendent
WTMA Water Dept.