

TO: WTMA Board of Directors
 FROM: Rodney Eberly, Water Superintendent
 DATE: May 15, 2015
 SUBJECT: Monthly Water Report for April 2015

This month the water system was operating at 46% of capacity.

	<u>MONTHLY</u>			<u>QUARTERLY</u>	
WATER PRODUCED:	16,738,000	GALLONS		52,110,000	GALLONS
WATER SOLD:				40,143,100	GALLONS
EST. LOSS FROM KNOWN LEAKS:	1,181,500	GALLONS	7%	5,997,500	GALLONS
* Note that the Monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak.					
EST. LOSS FROM FLUSHING, FIRE PROTECTION & BLOWOFFS:	375,000	GALLONS	2.24%	2,400,000	GALLONS
UNACCOUNTED WATER LAST OTR:				18%	
UNACCOUNTED WATER THIS QTR:				7%	
PREVIOUS SYSTEM CONNECTIONS:				2,398	
NEW CONNECTIONS THIS MONTH:				2	
TOTAL SYSTEM CONNECTIONS:				2,400	
TOTAL CONNECTIONS FOR 2014/2015				32/ 6	


NEW CONNECTION LOCATIONS:
 11571 Mystic Rock Lane North
 9945 Skittle Run Court

(A.) 1 Leak was discovered and repaired this month.
 Snyder Ave. Customer discovered leak. 1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. All winter blow offs were shut off at the beginning of the month.
2. Shut off notices were posted.
3. A fence was installed around the wellhead and contact tanks at Wells 5 & 6.
4. Operators serviced the caustic pump at Bubbling Springs.
5. All meters were read and high/low readings were rechecked.
6. All hydrant valves were exercised.
7. Operators used the line locator to trace several service lines.
8. Operators tapped the 8" water main on Old Pen Mar Road for a new lot.
9. The Water Department started to review the GIS mapping, verifying locations and adding missed infrastructure.

Respectfully Submitted,



Rodney Eberly
 Water Superintendent
 WTMA Water Dept.