

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: July 20, 2015
SUBJECT: Monthly Water Report for June 2015

This month the water system
was operating at 50% of capacity.

MONTHLY

WATER PRODUCED: 18,111,000 GALLONS

* Note that the Monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.

EST. LOSS FROM KNOWN LEAKS: 4,726,000 GALLONS 26.09%

EST. LOSS FROM FLUSHING, FIRE
PROTECTION & BLOW OFFS: 775,000 GALLONS 4.28%

PREVIOUS SYSTEM CONNECTIONS: 2,400

NEW CONNECTIONS THIS MONTH: 5

TOTAL SYSTEM CONNECTIONS: 2,405

TOTAL CONNECTIONS FOR 2014/2015 32/ 11

NEW CONNECTION LOCATIONS:

11636 Honey Run Lane	10295 Foxleigh Circle
11457 Buhman Drive West	11934 Deerfield Circle
10287 Foxleigh Circle	

(A.) 4 Leaks were discovered and repaired this month.

Monterey Circle, customer discovered leak.	1,181,500 gallons
Carrrosmar Farm Lane, staff discovered leak.	1,181,500 gallons
Norwood Ave, customer discovered leak.	1,181,500 gallons
Buena Vista Road, staff discovered leak.	1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. The 2" Chlorine feed line at Wells 5 & 6 was repaired.
2. A new service line was installed on the house at the back of Laurel Acres trailer park.
3. The meter was moved outside at 14215 Old 16. A new curb valve, setter and meter pit were installed.
4. Several lawns were repaired from previous leak repairs.
5. A new air conditioner was installed at Hoover Springs.
6. The new property boundary's were posted at Wells 5 & 6.
7. Operators blew off the water main in Monterey Circle.
8. Main line valve boxes were inspected and clean as needed.
9. Our meter replacement program continues as time permits.

Respectfully Submitted,



Rodney Eberly
Water Superintendent
WTMA Water Dept.