

TO: WTMA Board of Directors
FROM: Rodney Eberly, Water Superintendent
DATE: December 8, 2015
SUBJECT: Monthly Water Report for November 2015

This month the water system
was operating at 43% of capacity.

MONTHLY

WATER PRODUCED: 15,609,000 GALLONS
* Note that the Monthly loss from leaks is based on a calculation that can
be calculated up to 3 months depending on site description and certain characteristics of the leak.
EST. LOSS FROM KNOWN LEAKS: 2,363,000 GALLONS 15.14%
EST. LOSS FROM FLUSHING, FIRE
PROTECTION & BLOW OFFS: 1,250,000 GALLONS 8.01%
PREVIOUS SYSTEM CONNECTIONS: 2,413
NEW CONNECTIONS THIS MONTH: 1
TOTAL SYSTEM CONNECTIONS: 2,414
TOTAL CONNECTIONS FOR 2014/2015 32/ 20
NEW CONNECTION LOCATIONS:
9957 Skittle Run Court

(A.) 2 Leaks were discovered and repaired this month.

Pen Mar Road. Customer discovered leak. 1/4" hole. 1,181,500 gallons
Waterloo Road. Customer discovered leak. 1/4" hole. 1,181,500 gallons

(B.) Additional Maintenance / Repair Work.

1. Lawns that were disturbed from leak repairs were seeded and strawed.
2. The CL2 injector at Well 10 was rebuilt.
3. Operators repaired the barrel mixer at Bubbling Springs.
4. The screen and wet well at Hoover Springs was cleaned.
5. Tele-Plus installed security cameras for the Water Department.
6. Staff performed routine early winter maintenance at all stations.
7. The winter blow off valves were exercised to ensure operation.

Respectfully Submitted,



Rodney Eberly
Water Superintendent
WTMA Water Dept.