

TO: WTMA Board of Directors  
 FROM: Joe Schorn  
 DATE: May 10, 2019  
 SUBJECT: Monthly Water Report for April 2019

This month the water system was operating at 42% of capacity.

	MONTHLY		QUARTERLY	
WATER PRODUCED:	21,112,000	GALLONS	64,409,000	GALLONS
WATER SOLD:			27,886,000	GALLONS
(*1) EST. LOSS FROM KNOWN LEAKS:	2,661,500	GALLONS	3,843,000	GALLONS
(*2) EST. LOSS FROM FLUSHING, FIRE PROTECTION, BLOWOFFS & TANK OVERFLOWS:	1,036,800	GALLONS	2,111,800	GALLONS
UNACCOUNTED WATER LAST OTR:			41%	
UNACCOUNTED WATER THIS QTR:			47%	
PREVIOUS SYSTEM CONNECTIONS:			2,486	
NEW CONNECTIONS THIS MONTH:			1	
TOTAL SYSTEM CONNECTIONS:			2,487	
TOTAL CONNECTIONS FOR 2018/2019			28/ 6	
NEW CONNECTION LOCATIONS:	12454 Old Pen Mar Road			

(A.) 6 Leaks were discovered and repaired this month. The estimated total water loss from known leaks is above.

- 15577 Jacobs Church Road
- Intersection of Ressler Lane and Dutrow Lane
- 12170 Old Pen Mar Road
- 12312 Clermont Ave.
- 12046 Broad Street
- 13297 Grandview Ave.


(B.) Additional Maintenance / Repair Work.

1. In house leak detection was performed, and the leaks above were fixed in a timely manner.
2. Seeded and strawed yards from leaks that were fixed over the winter.
3. Serviced mower and mowed all of our locations.
4. All meters were read and high low readings were re-checked.
5. Serviced the 2015 F-350
6. Shut offs were posted and customers were shut off for non-payment.
7. Shoveled dirt and rocks out in front of the weir at wells 5&6 due to high flows in that creek.
8. Spring cleaning of all our locations.

(\*1) Note that the monthly loss from leaks is based on a calculation that can be calculated up to 3 months depending on site description and certain characteristics of the leak

(\*2) Note I added tank overflows to this line.

Respectfully Submitted,

  
 Joe Schorn  
 Director of Utilities